Marblehead IDDE Program Progress to Date

Reporting				
Period	Event	Location	Notes	
Jan-12	Public Awareness		Began newspaper advertisement	
Jan-12	Capped Underdrain	Ocean Ave/Wallace Ave	Capped July 11, 2011	
Jan-13	Unburied Manholes	Landfall Apartments	Unburied and documented two MHs	
Jul-13	Dye Testing	Village Plaza	No dye observed in drain lines	
Jul-13	Dye Testing	Landfall Apartments	No dye observed in drain lines	
Jan-14	Pipe Plugged	Lincoln Ave	Suspicious pipe connecting CB 2414 and MH 2458 plugged at both ends	
Jan-14	Underdrain	Jersey St	Custom fitting installed in MH 2165 to separate underdrain discharge from the drain channel	
Jul-14	Construction	Pleasant St	Phase I of Pleasant Street drainage project completed	
Jan-16	Sampling	Northern Zone	All samples in zone below EPA benchmark for enterococci	
Jul-16	Sewer Rehab	Southern Zone	Lining of sewer mains, laterals, and manholes	
Jan-17	Drain Lining	Central Zone	Lining of 33" RCP main drain line in Pleasant Street area	
Jan-17	Sewer Rehab	Central Zone	Dropped sewer line discovered and replaced on Hawkes St.	
Jul-17	Drain Lining	Central Zone	Lining of 4.5-ft by 4.5-ft stone culvert in Pleasant Street area	
Jul-17	Sewer Rehab	Central Zone	2 broken/leaking sewer services crossing through drain culvert on School Street found and repaired	
Jan-18	Sewer Rehab	Central Zone	2 broken/leaking sewer services repaired by Pleasant Street	
Jan-18	Drain Rehab	Central Zone	Replaced aging stone culvert/structures, Pleasant St Phase II	
Jan-19	Drain Rehab	Goldthwait Marsh	Repaired outlet, stabilized bank, installed DMH and 2 CBs, installed granite curbing	
Jun-20	Sampling	Town wide	Sampling conducted by Town and SSCW	
Jan-21	Public Education		RE-SUMP Program	
Jun-21	Public Awareness		Sustainable Marblehead Adopt-a-Drain	
Jun-21	Sampling	Town Wide	Sampling conducted by Town and SSCW	

Marblehead Illicit Discharges

Removed to Date

					Estimated		
Drain Structure	Street	Contamination Source	Pipe Size (in)	Pipe Material	Flow (gpd)	Removal Date	Removal Method
MH 22	Ocean Ave	Sewer Underdrain	6	VC	1440	July-11	Mechanical Plug
CB 2414	Lincoln Ave	Contaminated Infiltration	12	VC	2880	January-14	Mechanical Plugs
P 3141_3140	School St	Broken Sewer Service	4	CI	1440	July-17	Repair
P 3138_3140	School St	Leaking Sewer Service	4	CI	1440	July-17	Repair
				Total	7,200		

Marblehead IDDE Program Suspicious Structures

Suspicious Structures							
ID #	Туре	Date	Street	Reason	Notes		
23	СВ	Jan-18	Ocean	Possible discharge location of underdrain	Record DWGs 5, 64		
					2" pipe near bottom of culvert, orange gunk, stagnant water in		
25	MH	Jan-18	Wallace	Suspicious discharge	pipe		
29	MH	Jul-12	Bubier	Possible discharge location of underdrain	Record DWG 189		
29	MH	Jan-18	Bubier	Animal tracks	Raccoon tracks in pipes/culvert		
30	CB	Jul-12	Bubier	Possible discharge location of underdrain	Record DWG 189		
33	CB	Jul-14	Orchard	Unknown pipe	Pipe of unknown orgin in CB 33, no flow in either direction		
118	MH	Jul-12	Atlantic	Possible discharge location of underdrain	Record DWG 69; Natural bottom, possible underdrain		
					By Veterans School; whitish-grey substance found below joint of		
317	MH	Jul-14	Pleasant	Suspicious discharge	8" sewer pipe thru MH; no flow through DMH		
347	MH	Jan-18	Bubier	Animal tracks	Raccoon tracks in pipes		
358	MH	Jul-14	West Cottage	Not found, buried	MH sheet shows different pipes and MH location unknown		
361	MH	Jul-14	Pleasant	Unknown pipe	Pipe of unknown orgin, blocked by growth, to MH 358?		
					Moved during water main construction; custom fitting installed		
2165	MH	Jan-14	Jersey	Possible discharge location of underdrain	to separate underdrain discharge from drain channel		
					Pipe of unknown orgin, angled towards 28 Evans, high ammonia		
2168	MH	Jan-14	Jersey	Unknown pipe	levels		
2171	MH	Jul-13	Jersey	Possible discharge location of underdrain	Record DWG 59; nothing visible after cleaning		
2260		I. LAC	Discount	Current and the standing standard	Standing water with yellow bubbles, thick with floating brown		
2260	MH	Jul-16	Pleasant	Suspicious standing water	substance		
2264	CD.	I. LAC	Discount	Current and the standing standard	Standing water with yellow bubbles, thick with floating brown		
2261	CB	Jul-16	Pleasant	Suspicious standing water	substance		
2270	NALL.	1.1.1.0	Desser	Linkana sina	Unknown connections; small size makes it difficult to inspect manhole		
2270	MH	Jul-16 Jan-16	Bessom	Unknown pipe	Blockage causing water level in MH to rise above bench		
2302		J911-10	Green	Pipe blockage	Suspected infiltration entering between MH 2302 and MH 2303,		
2303	МН	Jan-16	Green	Groundwater infiltration	water clean		
2303	IVIII	Jan-10	Green		Wall wet/black substance under hole (old pipe connection?)		
2309	МН	Jan-16	Green	Suspicious discharge	covered in bricks		
2337-1	MH	Jul-12	Chestnut	Possible discharge location of underdrain	Record DWG 48; nothing visible under sewer		
2337-2	MH	Jul-12	Chestnut	Possible discharge location of underdrain	Record DWG 48; nothing visible under sewer		
2339	MH	Jul-12	Chestnut	Possible discharge location of underdrain	Record DWG 48; nothing visible under sewer		
					Leak under connection to CB 2414; Unknown pipe from		
2415	MH	Jan-16	Lincoln Ave	Leak/unknown pipe	direction of parking lot; old sidewalk drain connection		
2416	MH	Jan-16	Lincoln Ave	Old pipe connection	Old sidewalk drain connection		
					Pipe connecting MH 2428 to CB across street; Confirmed		
2428	MH	Jan-14	Hoods Lane	Groundwater infiltration	infiltration via visual inspection		
2430	CB	Jan-16	Hoods Lane	Suspicious discharge	Unknown pipe from direction of parking lot		
					Unknown pipe from direction of nearby building; dumpster next		
2432	MH	Jan-16	Lime	Suspicious discharge	to MH (grated top)		
2458	MH	Jan-14	Lincoln Ave	Buried MH	By 15 Lincoln Ave		
					High ammonia readings from discharging pipe coming from a		
2459	CB	Jan-14	Lincoln Ave	Connects to buried MH	buried MH on property of 15 Lincoln Ave		
	MH	Jan-14	Lincoln Ave	Buried MH	Under 15 Lincoln Ave driveway		
3659	MH	Jul-12	Deverux	Possible discharge location of underdrain	Record DWG 174; Combined sewer/drain; no underdrain		
3757	MH	Jul-14	Atlantic	Major infiltration around outgoing pipe	Test results show infiltration water is clean		
3820	CB	Jan-17	Central	Suspicious smell	Smells of sewage, standing grey water		
					Unknown pipe from direction of nearby home, invert lower than		
3824	CB	Jan-17	Central	Unknown pipe	outgoing pipe		
3837	MH	Jul-12	Chestnut	Possible discharge location of underdrain	Record DWG 48; nothing visible under sewer		
3838	MH	Jul-12	Chestnut	Possible discharge location of underdrain	Record DWG 48; nothing visible under sewer		