

2016 Test Results

HIGH SCHOOL

2 HUMPHREY ST

SAMPLE LOCATION	first draw Lead level (Pb Final)	30 second flush Lead Level (Pb Final)
A wing bubbler HW 2nd fl	<1.00 ug/L	<1.00 ug/L
D202 sink	<1.00 ug/L	<1.00 ug/L
D201-1 sink	<1.00 ug/L	<1.00 ug/L
D201-2 sink	<1.00 ug/L	<1.00 ug/L
D201-3 sink	<1.00 ug/L	<1.00 ug/L
D201-4 sink	<1.00 ug/L	<1.00 ug/L
D201-5 sink	<1.00 ug/L	<1.00 ug/L
D201-6 sink	<1.00 ug/L	<1.00 ug/L
D205 sink	<1.00 ug/L	<1.00 ug/L
D wing HW bubbler	<1.00 ug/L	<1.00 ug/L
A312 sink	<1.00 ug/L	<1.00 ug/L
A wing bubbler HW 3rd fl	<1.00 ug/L	<1.00 ug/L
B309 sink	<1.00 ug/L	<1.00 ug/L
main office kitchen sink	<1.00 ug/L	<1.00 ug/L
Gym HW bubbler	<1.00 ug/L	<1.00 ug/L
Gym bubbler 1	<1.00 ug/L	<1.00 ug/L
Gym bubbler 2	<1.00 ug/L	<1.00 ug/L
Cafe bubbler	<1.00 ug/L	<1.00 ug/L
D101 sink	<1.00 ug/L	<1.00 ug/L
A wing HW bubbler 1st fl	<1.00 ug/L	<1.00 ug/L
A112 sink	<1.00 ug/L	<1.00 ug/L
kitchen sink (3)	<1.00 ug/L	<1.00 ug/L
kitchen prep sink	<1.00 ug/L	<1.00 ug/L
nurses office sink	<1.00 ug/L	<1.00 ug/L

EPA - DEP ACTION LEVEL

15.5 ug/L

2018 Test Results

HIGH SCHOOL

2 HUMPHREY ST

SAMPLE LOCATION	first draw Lead level (Pb Final)	30 second flush Lead Level (Pb Final)
A wing bubbler HW 2nd fl	<1.00 ug/L	<1.00 ug/L
D202 sink	<1.00 ug/L	<1.00 ug/L
D201-1 sink	<1.00 ug/L	<1.00 ug/L
D201-2 sink	<1.00 ug/L	<1.00 ug/L
D201-3 sink	<1.00 ug/L	<1.00 ug/L
D201-4 sink	<1.00 ug/L	<1.00 ug/L
D201-5 sink	<1.00 ug/L	<1.00 ug/L
D201-6 sink	<1.00 ug/L	<1.00 ug/L
D205 sink	<1.00 ug/L	<1.00 ug/L
D wing HW bubbler	<1.00 ug/L	<1.00 ug/L
A312 sink	<1.00 ug/L	<1.00 ug/L
A wing bubbler HW 3rd fl	<1.00 ug/L	<1.00 ug/L
B309 sink	<1.00 ug/L	<1.00 ug/L
main office kitchen sink	<1.00 ug/L	<1.00 ug/L
Gym HW bubbler	<1.00 ug/L	<1.00 ug/L
Gym bubbler 1	<1.00 ug/L	<1.00 ug/L
Gym bubbler 2	<1.00 ug/L	<1.00 ug/L
Cafe bubbler	<1.00 ug/L	<1.00 ug/L
D101 sink	<1.00 ug/L	<1.00 ug/L
A wing HW bubbler 1st fl	<1.00 ug/L	<1.00 ug/L
A112 sink	<1.00 ug/L	<1.00 ug/L
kitchen sink (3)	<1.00 ug/L	<1.00 ug/L
kitchen prep sink	<1.00 ug/L	<1.00 ug/L
nurses office sink	<1.00 ug/L	<1.00 ug/L

EPA - DEP ACTION LEVEL

15.5 ug/L