

# 2016 Water Test Results

## VILLAGE SCHOOL

### 93 VILLAGE ST

SAMPLE LOCATION	first draw Lead level (Pb Final)	30 second flush Lead Level ( Pb Final)
Bubbler Library H.W	<1.00 ug/L	<1.00ug/L
Bubbler Art Rm	<1.00 ug/L	<1.00ug/L
Bubbler Music Rm	<1.00 ug/L	<1.00ug/L
Bubbler Door 21	<1.00 ug/L	<1.00ug/L
Bubbler Door 19	<1.00 ug/L	<1.00ug/L
Prin Sink	<1.00 ug/L	<1.00ug/L
Nurse Sink	<1.00 ug/L	<1.00ug/L
Bubbler Rm 27	<1.00 ug/L	<1.00ug/L
2nd Floor Bubbler	<1.00 ug/L	<1.00ug/L
3rd Fl Bubbler	<1.00 ug/L	<1.00ug/L
Kitchen Sink (3)	2.19 ug/L	<1.00ug/L
Kitchen Sink Sm	1.53 ug/L	1.40ug/L
Kitchen Sink Lg Sink	1.35 ug/L	1.02ug/l
Kitchen Sink Hand	1.82 ug/L	1.12ug/L
Room 118 Sink	<1.00 ug/L	<1.00ug/L
Cafe Bubbler 1	<1.00 ug/L	<1.00ug/L
Cafe Bubbler 2	<1.00 ug/L	<1.00ug/L

EPA - DEP ACTION LEVEL

15.5 ug/L