

**EVELETH SCHOOL
3 BROOK ROAD
2016 Sample Results**

SAMPLE LOCATION	first draw Lead level (Pb Final)	30 second flush Lead Level (Pb Final)
Room 10-101E	6.27 ug/L	
E-Teach 1	8.12 ug/L	
E106-1	3.09 ug/L	
E105-1	59.9 ug/L	3.97 ug/L
E104-1	7.98 ug/L	
E103-1	7.65 ug/L	
E102-1	7.03 ug/L	
E101-1	8.49 ug/L	
E107-1	27.5 ug/L	3.55 ug/L

EPA - DEP ACTION LEVEL 15.5 ug/L
 30 second flush sample completed test results recieved for 1st draw tests above action level

**EVELETH SCHOOL
3 BROOK ROAD
2019 Sample Results**

SAMPLE LOCATION	first draw Lead level (Pb Final)	30 second flush Lead Level (Pb Final)
Room 10-101E	4.83 ug/L	<1.0 ug/L
E-Teach 1	11.0 ug/L	1.21 ug/L
E106-1	19.7 ug/L	11.5 ug/L
E105-1	Disconnected	
E104-1	Drinking fountain removed Laundry sink only	
E103-1	37.3 ug/L	9.30 ug/L
E102-1	52.9 ug/L	7.40 ug/L
E101-1	24.7 ug/L	2.7 ug/L
E107-1	Disconnected	

EPA - DEP ACTION LEVEL 15.5 ug/L
 30 second flush sample completed test results recieved for 1st draw tests above action level