

Marblehead Community Charter School

17 Lime Street

SAMPLE LOCATION	first draw	30 second flush
	Lead level (Pb Final)	Lead Level (Pb Final)
kitchen sink A	12.0 ug/L	<1.00ug/L
kitchen sink B	5.16 ug/L	<1.00ug/L
Kitchen Sink C	2.58 ug/L	<1.00ug/L
Bubber A	2.59 ug/L	<1.00ug/L
Fill Station , Mailroom	<1.00ug/L	<1.00ug/L
Bubber B	<1.00ug/L	<1.00ug/L
Nurses Sink	1.00 ug/L	<1.00ug/L

EPA - DEP ACTION LEVEL 15.5 ug/L