

# 2016 Water Test Results

## ELDEBRIDGE GERRY SCHOOL

### 50 ELM STREET

SAMPLE LOCATION	first draw	30 second flush
	Lead level (Pb Final)	Lead Level ( Pb Final)
G101-1 B	4.54 ug/L	1.75ug/L
G201-B	5.43 ug/L	1.85ug/L
Basement Sink	6.09 ug/L	<1.00ug/L
Rm 5 Sink	5.11 ug/L	<1.00ug/L
Rm 9 Sink	4.75ug/L	4.11ug/L

EPA - DEP ACTION LEVEL

15.5 ug/L