

2016 Water Test Results

Glover School

4 MAPLE STREET

SAMPLE LOCATION	first draw	30 second flush
	Lead level (Pb Final)	Lead Level (Pb Final)
room 111 bubbler	<1.00 ug/L	<1.00ug/L
<1.00ug/L	<1.00 ug/L	1.03ug/L
Health office 101 sink	<1.00 ug/L	<1.00ug/L
room 113 bubbler	<1.00 ug/L	<1.00ug/L
room 115 bubbler	2.14 ug/L	<1.00ug/L
room 217 bubbler	1.05 ug/L	<1.00ug/L
room 119 bubbler	2.01 ug/L	<1.00ug/L
room 121 bubbler	1.90 ug/L	<1.00ug/L
room 123 bubbler	4.66 ug/L	<1.00ug/L
bubbler 1st fl bathroom	<1.00 ug/L	<1.00ug/L
room 125 bubbler	1.88 ug/L	<1.00ug/L
room 127 bubbler	1.46 ug/L	<1.00ug/L
room 129 bubbler	<1.00 ug/L	1.27ug/L
room 131 bubbler	3.30 ug/L	1.11ug/L
room 131 sink	<1.00 ug/L	<1.00ug/L
room 133 bubbler	1.32 ug/L	<1.00ug/L
room 135 bubbler	<1.00 ug/L	<1.00ug/L
room 138 bubbler	1.40 ug/L	<1.00ug/L
room 202 sink	<1.00 ug/L	<1.00ug/L
room 204 sink	<1.00 ug/L	<1.00ug/L
kitchen sink 3	<1.00 ug/L	<1.00ug/L
cafe bubbler	<1.00 ug/L	<1.00ug/L
HW gym bubbler	<1.00 ug/L	<1.00ug/L
room 211 bubbler	<1.00 ug/L	<1.00ug/L
room 213 bubbler	<1.00 ug/L	>1.00ug/L

SAMPLE LOCATION	first draw Lead level (Pb Final)	30 second flush Lead Level (Pb Final)
room 215 bubbler	<1.00 ug/L	<1.00ug/L
room 117 bubbler	1.14 ug/L	<1.00ug/L
room 219 bubbler	<1.00 ug/L	<1.00ug/L
room 221 bubbler	<1.00 ug/L	<1.00ug/L
room 223 bubbler	3.24 ug/L	<1.00ug/L
room 225 bubbler	<1.00 ug/L	<1.00ug/L
room 227 bubbler	<1.00 ug/L	<1.00ug/L
room 229 bubbler	<1.00 ug/L	<1.00ug/L
room 231 bubbler	<1.00 ug/L	<1.00ug/L
room 239 sink	<1.00 ug/L	<1.00ug/L
room 233 bubbler	<1.00 ug/L	<1.00ug/L
room 235 bubbler	<1.00 ug/L	<1.00ug/L
room 238 bubbler	<1.00 ug/L	<1.00ug/L
bathroom bubbler 225	<1.00 ug/L	<1.00ug/L
bathroom bubbler 211	<1.00 ug/L	<1.00ug/L

EPA - DEP ACTION LEVEL

15.5 ug/L